

Ruj. Kami : SPAN/BPAI/300-10/422/A/W-3  
Tarikh : 04 Jul 2022

ENGTEX SDN. BHD.  
LOT 36, JALAN BRP 9/2B,  
PUTRA INDUSTRY PARK,  
BUKIT RAHMAN PUTRA,  
SG BULOH,  
47000 SELANGOR DARUL EHSAN  
(U/P: CIK CIK JESSICA TIEW)

Tuan,

**PERAKUAN PENYENARAIAN PEMBEKAL UNTUK PRODUK-PRODUK KEGUNAAN INDUSTRI PERKHIDMATAN AIR**

Perkara di atas adalah dirujuk.

2. Sukacita dimaklumkan bahawa syarikat tuan telah disenaraikan sebagai pembekal produk-produk kegunaan industri perkhidmatan air seperti berikut:

Bil	No Penyenaraian SPAN	Kegunaan	Produk	Jenama	Maklumat Sijil Barangan		
					No. Sijil	Standard	Tempoh Sah Laku
1	SPAN/BPAI/300-10/422/A/W-3	Sistem Bekalan Air	FITTINGS - MANHOLE COVER	LYE, ESB & WAGO	SIRIM PC004510 Pengilang: HANDAN QUNSHAN FOUNDRY CO., LTD.	BS EN 124-2:2015	26 Jul 2023

3. Penyenaraian adalah **tertakluk sepenuhnya mengikut skop dan tempoh sahlaku sijil barangan** yang dikemukakan kepada SPAN. Penyenaraian ini juga tertakluk kepada syarat-syarat khusus yang telah ditetapkan seperti yang dinyatakan di dalam lampiran sekiranya ada.

4. Syarikat yang memasuki penyenaraian ini adalah **bertanggungjawab** untuk **memastikan bahawa sijil barangan adalah sah (valid)** pada sepanjang penyenaraian dan **mengemaskini maklumat sijil barangan** kepada SPAN setiap kali pembaharuan sijil dibuat atau sekiranya terdapat perubahan pada skop pensijilan.

**Suruhanjaya Perkhidmatan Air Negara**

Ground & 1<sup>st</sup> Floor, Prima Avenue 7, Block 3510,  
Jalan Teknokrat 6, 63000 Cyberjaya, Selangor, Malaysia  
T 603 8317 9333/334/335 F 603 8317 9336/339  
W [www.span.gov.my](http://www.span.gov.my)



5. **Kegagalan tuan untuk mematuhi keperluan (4) boleh menyebabkan syarikat tuan dikeluarkan daripada penyenaian tanpa sebarang notis.** Produk yang telah dikeluarkan daripada senarai penyenaian adalah tidak dibenarkan untuk diguna pakai dalam mana-mana sistem bekalan air atau pembedungan di Semenanjung Malaysia, Wilayah Persekutuan Putrajaya dan Labuan.

Sekian, terima kasih.

Yang benar,



( Mohamad Nasir bin Mahmood )  
Pengarah Kanan  
Bahagian Pembangunan dan Audit Industri  
Suruhanjaya Perkhidmatan Air Negara (SPAN)

No Listing : SPAN/BPAI/300-10/422/A/W-3

Tarikh : 04 Jul 2022



**PERAKUAN PENYENARAIAAN PEMBEKAL  
SYARAT-SYARAT KHUSUS**

PRODUCT : FITTINGS - MANHOLE COVER

STANDARD : BS EN 124-2:2015

TIADA

No Listing : SPAN/BPAI/300-10/422/A/W-3

Tarikh : 04 Jul 2022



### PERAKUAN PENYENARAIAAN PEMBEKAL

PEMBEKAL : ENGTEX SDN. BHD.  
 : LOT 36, JALAN BRP 9/2B,  
 PUTRA INDUSTRY PARK,  
 BUKIT RAHMAN PUTRA,  
 SG BULOH,  
 47000 SELANGOR DARUL EHSAN

PRODUK : FITTINGS - MANHOLE COVER

Model-model yang diluluskan oleh SPAN adalah seperti di bawah

No	Model	Series	Description
1	ROUND DESIGN COVER		TYPE : MATERIAL: DUCTILE IRON EN-GJS-500-7; MANHOLE WITH INTERLOCKING DEVICE. RATING : GROUP 4; CLASS: D400; CLEAR OPENING: MINIMUM 600mm; FIRE RATING CLASS: NO PERFORMANCE DETERMINED (NPD). SIZE : FRAME SIZE: 840mm X 840mm X 100mm (H); DEPTH OF INSERTION: 50mm.
2	ROUND DESIGN COVER		TYPE : MATERIAL: DUCTILE IRON EN-GJS-500-7; MANHOLE WITH INTERLOCKING DEVICE. RATING : GROUP 4; CLASS: D400; CLEAR OPENING: MINIMUM 600mm; FIRE RATING CLASS: NO PERFORMANCE DETERMINED (NPD). SIZE : FRAME SIZE: 840mm X 840mm X 100mm (H); DEPTH OF INSERTION: 32mm.
3	ROUND DESIGN COVER		TYPE : MATERIAL: DUCTILE IRON EN-GJS-500-7; MANHOLE WITH INTERLOCKING DEVICE. RATING : GROUP 4; CLASS: D400; CLEAR OPENING: MINIMUM 600mm; FIRE RATING CLASS: NO PERFORMANCE DETERMINED (NPD). SIZE : FRAME SIZE: 840mm X 840mm X 150mm (H); DEPTH OF INSERTION: 37mm.
4	ROUND DESIGN COVER		TYPE : MATERIAL: DUCTILE IRON EN-GJS-500-7; MANHOLE WITH INTERLOCKING DEVICE. RATING : GROUP 2; CLASS: B125; CLEAR OPENING: MINIMUM 600mm; FIRE RATING CLASS: NO PERFORMANCE DETERMINED (NPD). FRAME SIZE: 840mm X 840mm X 50mm (H); DEPTH OF INSERTION: 43mm.
5	ROUND DESIGN COVER		TYPE : MATERIAL: DUCTILE IRON EN-GJS-500-7; MANHOLE WITH INTERLOCKING DEVICE. RATING : GROUP 3; CLASS: C250; CLEAR OPENING: MINIMUM 600mm; FIRE RATING CLASS: NO PERFORMANCE DETERMINED (NPD). SIZE : FRAME SIZE: 710mm X 710mm X 100mm (H); DEPTH OF INSERTION: 40mm
6	ROUND DESIGN COVER		TYPE : MATERIAL: DUCTILE IRON EN-GJS-500-7; MANHOLE WITH INTERLOCKING DEVICE. RATING : GROUP 2; CLASS: B125; CLEAR OPENING: MINIMUM 600mm; FIRE RATING CLASS: NO PERFORMANCE DETERMINED (NPD). SIZE : FRAME SIZE: 710mm X 710mm X 50mm (H); DEPTH OF INSERTION: 43mm.

7	ROUND DESIGN COVER		TYPE : MATERIAL: DUCTILE IRON EN-GJS-500-7; MANHOLE WITH INTERLOCKING DEVICE. RATING : GROUP 2; CLASS: B125; CLEAR OPENING: MINIMUM 508mm; FIRE RATING CLASS: NO PERFORMANCE DETERMINED (NPD). SIZE : FRAME SIZE: 610mm X 610mm X 80mm (H); DEPTH OF INSERTION: 44mm.
8	ROUND DESIGN COVER		TYPE : MATERIAL: DUCTILE IRON EN-GJS-500-7; MANHOLE WITH INTERLOCKING DEVICE. RATING : GROUP 2; CLASS: B125; CLEAR OPENING: MINIMUM 508mm; FIRE RATING CLASS: NO PERFORMANCE DETERMINED (NPD). SIZE : FRAME SIZE: 610mm X 610mm X 50mm (H); DEPTH OF INSERTION: 43mm.
9	ROUND DESIGN COVER		TYPE : MATERIAL: DUCTILE IRON EN-GJS-500-7; MANHOLE WITH INTERLOCKING DEVICE. RATING : GROUP 3; CLASS: C250; CLEAR OPENING: MINIMUM 442mm; FIRE RATING CLASS: NO PERFORMANCE DETERMINED (NPD). SIZE : FRAME SIZE: 530mm X 530mm X 76mm (H); DEPTH OF INSERTION: 43mm
10	ROUND DESIGN COVER		TYPE : MATERIAL: DUCTILE IRON EN-GJS-500-7; MANHOLE WITH INTERLOCKING DEVICE. RATING : GROUP 4; CLASS: D400; CLEAR OPENING: MINIMUM 320.3mm; FIRE RATING CLASS: NO PERFORMANCE DETERMINED (NPD). SIZE : FRAME SIZE: 440mm X 440mm X 609mm (H); DEPTH OF INSERTION: 18mm.