

## CERTIFICATE OF ANALYSIS

Date: 13 December 2017

Product Name : SNOWICE 410A  
Production Date : 23/10/2017  
Lot Number : WRD 080-1017 43117  
Lot Quantity : 50Pcs @ 10kg  
Packing List No : -

Test Items	Specification	Analytical Results
Purity	99.5% min.	> 99.5%
Composition	R125: 50.0% (+1.5, -0.5%)	Pass
	R32: 50.0% (+0.5, -1.5%)	
Water Content	10 ppm max.	< 10 ppm
Acidity as in HCL	1.0 ppm max.	< 1.0 ppm
Non-Condensables	1.5% max.	< 1.5%
High Boiling Residue	0.01% max.	< 0.01%
Chloride	Pass	Pass
Particulate / Solids	Clear & Colorless	Pass



Checked by



Reviewed by

**Disclaimer:**

The technical data provided on the above sample is done as a service and the results carry measurement uncertainties. The report represents interpretation of result obtained from test specimen and is not to be construed as a guarantee or warranty of the condition of the entire material lot. Since conditions of its use are outside of our control, we will assume no liability for the use of such information or any damages incurred through its use or application. Nothing contained in above data, information and results is to be construed as contractual or providing some form of warranty on our part.