

# CERTIFICATE OF ANALYSIS

Product: R508B

Batch No.:1-2105153

Standard: GB/T18826-2002

The date of production: 2021.05.16

Items	Unit	Index	Inspection Results
Appearance		Colorless and no turbid	Qualified
Odor		No strange stench	Qualified
Purity	% ( $\geq$ )	99.9	99.92
R23%		46	46
R116%		54	54
Moisture	% ( $\leq$ )	0.001	0.0009
Acidity	(as HCL) %	0.001	<0.001
Vapor Residue	% ( $\leq$ )	0.01	<0.01
Conclusion		Excellent Grade	