

CULMI AIR-COND & REFRIGERATION PARTS SUPPLY SDN BHD



Date : 1-05-12

STC200 Temperature Controller Wiring Condition

- 1) Setting Temp : 20 °C (Temp. To Maintain)
- 2) Temp Diff. Setting : 3 °C
- 3) Comp. Delay Time: 3 Minutes
- 4) Comp. Cut Off : At 20 °C
- 5) Comp. Cut In : At 23 °C or 3 minutes later



Applicable For Air & Water



Probe

To be connected to Relay for sending signal to cut in and out of the compressor.

Setting item	Parameter setting range	Default	Code
Temperature differential setting	1°C~16°C	3°C	F0
Compressor delay time	0~9Minute	3Minutes	F1
Temp. lower limit setting	-40°C~set temperature	-20°C	F2
Temp. upper limit setting	Set temperature~70°C	20°C	F3
Mode optional	1: refrigeration 2:heating 3: alarm	1	F4
Temperature calibration	-5°C~+5°C	0	F5

2

3

Either One Function