



ANALYSIS CERTIFICATE

DATE: AUG. 27, 2014

TO: WHOM IT MAY CONCERN

DESCRIPTION OF GOODS: REFRIGERANT 134A

PACKING: IN 13.6KGS CYLINDER

INV. NO: FHGS140730

TEST ITEMS	Specification	Analysis Results
Inspection Standard	GB/T 18826-2002	
Appearance	Clear, Colorless and Odorless	Clear, Colorless and Odorless
Purity, % by weight	≥ 99.9	99.9
Moisture, % by weight	≤ 0.001	0.0007
Acidity (as in HCL), % by weight	≤ 0.0001	undetected
Residue on Evaporation, % by weight	≤ 0.01	0.0005
Non-condensable Gas, % by volume	≤ 1.5	0.4
Chlorides, % by volume	Pass	Pass