

80247387



## CERTIFICATE OF ANALYSIS

### FORANE 407C

Date :

02.03.2012

Components	Unit	Specifications	Analytical Result
Forane 32	%	23 +/- 2%	24.2
Forane 125	%	25 +/- 2%	24.4
Forane 134a	%	52 +/- 2%	51.4
Purity	% by weight	≥ 99.5	99.9
Moisture	ppm by weight	≤ 10	10
Total Acidity (HCl)	ppm by weight	≤ 1	NON
Chloride Ion Test	ppm by weight	Negative	Pass
Air in vapor phase in filled container	% by volume	≤ 1.5%	0.03
High Boiling Residue	ppm by weight	≤ 50	10

LOT NO.  
F120439STK

THIS IS A COMPUTER GENERATED REPORT. NO SIGNATURE IS REQUIRE.