

Danfoss A/S DK-6430 Nordborg Denmark

CVR nr.: 20 16 57 15 Telephone: +45 7488 2222

Danfoss Poland Sp. z o.o.

ul. Chrzanowska 5 05-825 Grodzisk Mazowiecki

> Telefon: +48 22 755 07 00 Telefax: +48 22 755 07 01

> > info@danfoss.com www.danfoss.pl

## PRESSURE SETTING CERTIFICATE

It is hereby certified that following safety valves have been tested and adjusted to the specified Set pressure. The safety valves are type approved according to Pressure Equipment Directive 2014/68/EU Category IV by notified body TÜV NORD 0045.

Quantity	Part No	Туре	Serial No.	Set pressure [bar g]
2 pcs	148F3238	SFA15	956574 - 956575	38

Each valve is marked with:

Serial number, Inlet size, Production date, Set pressure, Manufacture, CE-mark and Approval number. After adjustment to state Set pressure the valve have been sealed, The seal has been stamped with.





P. Order No.

Jaroslaw Strzelczyk

13-09-2023

Head, Operations

Date

The quality level of Danfoss A/S Products is continuously monitored and assured through our quality system. Danfoss A/S registered by Bereau Veritas Certification as having a Quality Assurance System complying with requirements in ISO 9001 and as having an Environmental Manage-ment System complying with ISO14001.

Our products comply with the requirements of the Pressure Equipment Directive 2014/68/EU and are approved by TÜV NORD (0045).

The certificate has been electronically generated by competent personnel according to procedure