

Certificate of Test

Issued to:

MSB Storage Battery Manufacturing S/B

Item Tested:

Ultra Valve Regulated Lead-acid Batteries

Models:

MS12-100 and MS2-300

No. of Samples Tested:

18 batteries of each model

The sample batteries were evaluated on 5 test procedures specified in IEC 896-2: 1995. The test schedules and results are tabulated below:

Test Number	Schedule	Result	
		MS12-100	MS2-300
1	Capacity test (Clause 5.1)	Conformity	Conformity
2	Test of suitability for float battery operation (Clause 5.2)	Conformity	Conformity
3	Test for endurance in discharge/charge cycles (Clause 5.3)	34 cycles	66 cycles
4	Test for charge retention (Clause 5.4)	Conformity	Conformity
5	Test (Clause 5.5) - short circuit current - internal resistance	2170 A 5.79 mohm	3450 A 0.613 mohm

For tests (Numbers 1, 2 and 4) where the IEC Standard requires a result at least in agreement with the manufacturer's claimed performance in published literature, the samples conformed. Where only the test result needed to be recorded (Test Numbers 3 and 5) the average values are tabulated above.

Signed:.:

A Austin

Principal Engineer

Date of tests: April 2002 to January 2003

Date of issue: 30th January 2003

ITS Report No. 02006972/Issue 1

Serial No: 03 1033

MSB Storage Battery Manufacturing S/B

No. 2a, Jalan TPP 5/2 Taman Perindustrian

Puchong

Section 5, 47100 Puchong

Selangor Darul Ehsan

Malaysia

