


Certificate of Conformity

Issued to: Gabungan Sumber Tenaga Sdn. Bhd
Item Tested: L Type Nickel-Cadmium Battery Cells
Models: HKP5, HKP12 and HKP36
No. of Samples Tested: 21 cells of each model

Samples were tested to, and found to be in conformity with, the following type approval test procedures specified in BS EN 60623: 2001:

Test	Clause or Sub-Clause
1. Marking	2.3
2. Dimensions	3.0
3. Rated discharge at 20°C	4.2.1
4. High rate current	4.2.4
5. Endurance in cycles (300 cycles)	4.4.1
6. Charge acceptance	4.5
7. Charge retention	4.3

Signed: 
M Conboy
Manager

Date of tests: June to December 2002
Date of issue: 30th January 2003

ITS Report No. 02007258/Issue 1
Serial No: 03 1032
Gabungan Sumber Tenaga Sdn. Bhd
No. 220, Jalan 1
Taman Perindustrian Ehsan Jaya
52100 Kepong
Kuala Lumpur
Malaysia



ITS Testing & Certification Ltd

ITS House, Cleve Road, Leatherhead, Surrey KT22 7SE

Tel: +44 (0)1372 370000 Fax: +44 (0)1372 370999

Registered No. 3272201 Registered office: 25 South Row, London W1R 1AA

For terms and conditions please see reverse