



Personal Protective Equipment	Low Medium Voltage	Lines, cabins and cabinet
-------------------------------	--------------------	---------------------------

Code: **GI – DIELECTRIC GLOVES**



**Dielectric gloves certified as Personal Protective Equipment in compliance with the International Standard IEC 60903**

Insulating gloves in natural latex.



In conformity with	IEC 60903
--------------------	-----------

Type	<b>GI 2.5</b>
Class	00
Length	36 cm / 41 cm
Voltage test	2500 V
Max operating voltage	500 V

Type	<b>GI 5</b>
Class	0
Length	36 cm / 41 cm
Voltage test	5000 V
Max operating voltage	1000 V

Type	<b>GI 10</b>
Class	1
Length	36 cm / 41 cm
Voltage test	10000 V
Max operating voltage	7500 V

Type	<b>GI 20</b>
Class	2
Length	36 cm / 41 cm
Voltage test	20000 V
Max operating voltage	17000 V

Type	<b>GI 30</b>
Class	3
Length	36 cm / 41 cm
Voltage test	30000 V
Max operating voltage	26500 V

Type	<b>GI 40</b>
Class	4
Length	41 cm
Voltage test	40000 V
Max operating voltage	36000 V

Accessories	
<b>CUST/GI</b>	Insulating plastic case for transport or for fixing to the wall