



No Lesen : FL000002

Licence No :

## SIJIL BARANGAN TERSENARAI

*Product Listing Certificate*



SIRIM

SIRIM QAS International Sdn. Bhd. dengan ini menganugerahkan kepada  
*SIRIM QAS International Sdn. Bhd. hereby grants to*

**K-FLEX MALAYSIA SDN BHD**  
**LOT 2752, JALAN RAJA NONG**  
**TAMAN KLANG JAYA**  
**41200 KLANG**  
**SELANGOR, MALAYSIA**

**Sijil untuk menggunakan Tanda Barangan Tersenarai**

*a certificate to use the Listed Product Mark on*

**ELASTOMERIC THERMAL INSULATION**

**Please refer to detail in the SCHEDULE**

**sebagai mematuhi keperluan**

*as complying with*

**BS 476 : PART 6 : 1989**

**BS 476 : PART 7 : 1997**

**Mohd Azanuddin bin Salleh**  
Ketua Pegawai Eksekutif  
*Chief Executive Officer*  
SIRIM QAS International Sdn. Bhd.

SIRIM QAS International Sdn. Bhd.  
(No. Syarikat 410334-X)  
1, Persiaran Dato' Menteri  
Seksyen 2, Peti Surat 7035  
40700 Shah Alam  
Selangor Darul Ehsan  
MALAYSIA.

Tel : 60-3-55446400  
Faks : 60-3-55446466

<http://www.sirim.my>

<http://www.malaysiancertified.com.my>

**Tarikh Mula Pensijilan : 20 January 2012**

*Certified Since*

**Sah Sehingga : 20 January 2021**

*Valid Until*

**Tarikh Dikeluarkan : 09 December 2019**

*Issue Date*

**No Siri : 051271**

*Serial No*

Lesen ini dianugerahkan tertakluk kepada syarat-syarat Perjanjian Pensijilan Barangan SIRIM QAS International Sdn. Bhd.

*This Licence is granted subject to the provisions of the Product Certification Agreement of SIRIM QAS International Sdn. Bhd.*

## SCHEDULE

### K-FLEX MALAYSIA SDN BHD



Trade Mark : K-FLEX  
Model : EC  
Rating : Nominal Density: 50 kg/m<sup>3</sup> (Thickness: 10 mm, 19 mm), 58 kg/m<sup>3</sup> (Thickness: 32 mm)  
Fire Propagation Index, I: 1.7, 1.9, 3.6  
Surface Spread of Flame: Class One  
Type : Tube & Sheet  
Size : Nominal thickness:: 10mm, 19mm & 32mm

TEST REPORT NO. : 2016FE0470, 2016FE0471, 2016FE0472, 2016FE0473,  
2016FE0474, 2016FE0475

---

*End of page*

---