



No Lesen : PC002367

Licence No :

## LESEN PENSIJILAN BARANGAN

*Product Certification Licence*



SIRIM QAS International Sdn. Bhd. dengan ini menganugerahkan kepada  
*SIRIM QAS International Sdn. Bhd. hereby grants to*

**LEADER PARTS ENTERPRISE SDN. BHD.**  
LOT 1800 & 1805, JALAN KPB 5  
KAWASAN PERINDUSTRIAN BALAKONG  
43300 SERI KEMBANGAN  
SELANGOR, MALAYSIA

Lesen untuk menggunakan Tanda Pensijilan di atas barangan  
*a licence to use the Certification Mark on*

**SEAMLESS PLAIN COPPER TUBE**

Please refer to detail in the SCHEDULE

sebagai mematuhi keperluan  
*as complying with*

**JIS H 3300 : 2012**

**Mohd Azanuddin bin Salleh**  
Ketua Pegawai Eksekutif  
*Chief Executive Officer*  
SIRIM QAS International Sdn. Bhd.

SIRIM QAS International Sdn. Bhd.  
(No. Syarikat 410334-X)  
1, Perstarian Dato' Menteri  
Seksyen 2, Peti Surat 7035  
40700 Shah Alam  
Selangor Darul Ehsan  
MALAYSIA.

Tel : 60-3-55446400  
Faks : 60-3-55446466

<http://www.sirim.my>  
<http://www.malaysiancertified.com.my>

Tarikh Mula Pensijilan : 10 June 2016  
*Certified Since*  
Sah Sehingga : 10 June 2020  
*Valid Until*

Tarikh Dikeluarkan : 26 June 2019  
*Issue Date*  
No Siri : 047340  
*Serial No*

Lesen ini dianugerahkan tertakluk kepada syarat-syarat Perjanjian Pensijilan Barangan SIRIM QAS International Sdn. Bhd.  
*This Licence is granted subject to the provisions of the Product Certification Agreement of SIRIM QAS International Sdn. Bhd.*

## SCHEDULE

### LEADER PARTS ENTERPRISE SDN. BHD.



Trade Mark : MEGAATUBE  
Model : GRADE = C1220 T-H  
Type : COPPER TUBE IN STRAIGHT LENGTH  
Size : OUTSIDE DIAMETER (mm) X WALL THICKNESS (mm) = 6.35 x (0.71,0.81,0.91)  
, 9.53 x (0.71,0.81,0.91), 12.70 x (0.71,0.81,0.91), 15.88 x (0.71,0.81,0.91)  
, 19.05 x (0.71,0.81,0.91), 22.23 x (0.71,0.81,0.91), 28.58 x (0.71,0.81,0.91,1.22),  
34.93 x (0.71,0.81,0.91,1.22), 41.28 x (0.81,0.91,1.02,1.22), 53.98 x (1.02,1.22),  
66.68 x 1.22, 79.38 x (1.22,2.29)

Trade Mark : MEGAATUBE  
Model : GRADE = C1220 T-O  
Type : COPPER TUBE IN COIL  
Size : OUTSIDE DIAMETER (mm) X WALL THICKNESS (mm) = 6.35 x (0.51, 0.56, 0.61,  
0.71, 0.81, 0.91), 9.53 x (0.51, 0.56, 0.61, 0.71, 0.81, 0.91), 12.70 x (0.51, 0.56,  
0.61, 0.71, 0.81, 0.91), 15.88 x (0.56, 0.61, 0.71, 0.81, 0.91), 19.05 x  
(0.61, 0.71, 0.81, 0.91)