



NATIONAL PHYSICAL LABORATORY

Teddington Middlesex UK TW11 0LW Telephone +44 20 8977 3222

NPL Management Ltd – Registered in England and Wales No 2937881

Test Report

Determination of Attenuation Properties of Materials using Diagnostic X-Radiation

The measurement results in this report are traceable to the SI system of units, to units of measurement realised at the National Physical Laboratory or other recognised national metrology institutes, or to other internationally recognised standards. This test report may only be published in full, unless permission for the publication of an approved extract has been obtained in writing from NPL Management Ltd. The data included in this report applies only to those items specifically listed as tested, calibrated or sampled and cannot be used to assign any attributes beyond those shown by the data.

FOR:

Kemmetech Ltd
Unit 4, Arnold Business Park
Branbridges Road
East Peckham
Tonbridge
TN12 5LG

DESCRIPTION:

Determination of attenuation properties of material according to BS EN 61331-1:2014 using the modified Broad Beam Geometry (Eder and Schlattl, 2018¹)

DATE OF MEASUREMENTS: 16 June to 07 August 2023

REPLACEMENT FOR TEST REPORT REFERENCE NO 2023070325_2

Reference: 2023070325_2R

Page 1 of 3

Date of Issue: 04 December 2023

Signed:

(Authorised signatory)

Checked by:

[Handwritten signature]
[Handwritten signature]

Name: G A Bass

on behalf of NPLML

CONDITIONS:

Distance from x-ray tube to target sample: 0.8m
 Ionisation chamber used: PTW TW34069-2.5 s/n 000231

All equipment associated with the measurements performed in this report has direct traceability to UK national standards or UKAS accredited calibration facilities.

Table I
 61331-1:2014 X-ray beam qualities

<u>X-ray Tube Voltage</u> kV	<u>Added filtration</u> mmAl*
50 - 150	2.2

*The inherent filtration of the x-ray tube was determined to be 0.3mmAl equivalent (according to ISO 4037-1:1996), giving a total filtration of 2.5mmAl

F_{mBBG} is the attenuation ratio in the modified Broad Beam Geometry¹, given by:

$$F_{mBBG} = \frac{\dot{K}_0 - \dot{K}_B}{\dot{K}_1 - \dot{K}_B}$$

where \dot{K}_0 = Air Kerma Rate without the test object in the beam

\dot{K}_1 = Air Kerma Rate with the test object in the beam

\dot{K}_B = Background Air Kerma Rate with the test object replaced by a sheet of material with an attenuation ratio greater than 10^5 .

F_{mBBG} can be converted to % attenuation by

$$\% \text{ attenuation} = \left(1 - \left(\frac{1}{F_{mBBG}} \right) \right) \times 100$$

The Lead equivalent value δ_{mBBG} in mm using the Modified Broad Beam Geometry is obtained by fits to the attenuation curves F_{mBBG} of Lead foils of known thicknesses and of at least 99.995% purity.

UNCERTAINTIES

The uncertainty in the Lead equivalence value δ_{mBBG} is $\pm 5\%$. The reported expanded uncertainty is based on a standard uncertainty multiplied by a coverage factor $k = 2$, providing a level of confidence of approximately 95%.

REFERENCES

1. IEC 61331-1: A new setup for testing lead free X-ray protective clothing, Heinrich Eder and Helmut Schlattl, *Physica Medica* 45 (2018) 6–11

RESULTS:

Table II

Lightweight Lead, sample #253, 0.25mm nominal Lead equivalent
Measured Area density: 3.43kg/m²

kV	F_{mBBG}	δ_{mBBG} mm	PASS/FAIL†
60	43.0	0.2539	PASS
70	23.6	0.2584	PASS
90	10.7	0.2595	PASS
110	7.46	0.2611	PASS

Table III

Lightweight Lead, sample #254, 0.35mm nominal Lead equivalent
Measured Area density: 4.81kg/m²

kV	F_{mBBG}	δ_{mBBG} mm	PASS/FAIL†
60	109	0.3522	PASS
70	49.9	0.3594	PASS
90	17.7	0.3586	PASS
110	11.9	0.3610	PASS

Table IV

Lightweight Lead, sample #255, 0.50mm nominal Lead equivalent
Measured Area density: 6.89kg/m²

kV	F_{mBBG}	δ_{mBBG} mm	PASS/FAIL†
60	369	0.5008	PASS
70	124	0.4999	PASS
90	33.6	0.5060	PASS
110	21.4	0.5048	PASS

†Determination of the lead equivalent class for a specified range of radiation qualities according to IEC 61331-1 clause 5.5.

Clause 5.5.3 of IEC 61331-1:2014 states that a relative standard uncertainty of 7% be taken into account in the decision of conformity in assigning the class of the Lead equivalent thickness to the material under test. If t_{Pb} is the standard Lead equivalent thickness class (0.25mm, 0.35mm, 0.5mm or 1mm) and δ_{IB} is the Lead equivalence of the material under test, the condition can be written as:

$$\delta_{IB} \geq 0.93t_{Pb}$$

The Lead equivalence in the Inverse Broad Beam geometry, δ_{IB} has been replaced with δ_{mBBG} for this determination.

CHANGES TO TEST REPORT:

The material product names have been amended in the results tables above.

MM
DJM