



Registration Details

SPAN Listing No. : 300-10/356/A/W-16

Supplier : **WELL BUILT ALLOY INDUSTRIES SDN. BHD. - 76460-D**

NO. 5 JALAN RIANG 24 TAMAN GEMBIRA 81200 JOHOR BAHRU JOHOR DARUL TAKZIM Tel: 6073329173 /Fax: 6073328664

Manufacturer : WELL-BUILT ALLOY INDUSTRIES SDN BHD NO. 5 JALAN RIANG 24 TAMAN GEMBIRA 81200 JOHOR BAHRU JOHOR DARUL TAKZIM

Principal : WELL-BUILT ALLOY INDUSTRIES SDN BHD NO. 5 JALAN RIANG 24 TAMAN GEMBIRA 81200 JOHOR BAHRU JOHOR DARUL TAKZIM

Category : A (WATER)

Group : FLOW CONTROL

Product : VALVE

Type : SERVICING VALVE / LOCKABLE VALVE

Sub-type : NA

Details Information

Model	Series	Description
BALL VALVE	BALL VALVE; PATTERN: SPHERICAL PLUG; FULL BORE	BODY MATERIAL CW614N & CW617N; END CONNECTION: SCREW ENDS; LEVER OPERATED MAXIMUM WORKING PRESSURE" 25BAR; MAXIMUM WORKING TEMPERATURE: 30C NORMINAL SIZE: 1/4", 3/8", 1/2", 1", 1 1/4", 1 1/2", 2", 2 1/2", 3" & 4"
BALL VALVE	BALL VALVE; PATTERN: SPHERICAL PLUG; REDUCE BORE	BODY MATERIAL CW614N & CW617N; END CONNECTION: SCREW ENDS; LEVER OPERATED MAXIMUM WORKING PRESSURE" 25BAR; MAXIMUM WORKING TEMPERATURE: 30C NORMINAL SIZE: 1/4", 3/8", 1/2", 1", 1 1/4", 1 1/2", 2", 2 1/2", 3" & 4"
MINI BALL VALVE	MINI BALL VALVE PATTERN: SPHERICAL PLUG; MINI BALL	BODY MATERIAL CW614N & CW617N; END CONNECTION: SCREW ENDS; LEVER OPERATED MAXIMUM WORKING PRESSURE" 25BAR; MAXIMUM WORKING TEMPERATURE: 30C NORMINAL SIZE: 1/2"

Brands : CITY

Standard : BS 6675:1986

Certificate body & Certificate No	: WATERMARK WCMPL000004
Certification Scope	: VALVE-SERVICING VALVE / LOCKABLE VALVE-NA
Valid Until	: 2024/10/31

This report is computer generated and no signature is required. SPAN will not responsible for any misuse of this report. Please contact SPAN at 03-83179333/334/335 for verification of any information established in this report.