



PASS

Decay Test Result

459.6 Microns

Final Vacuum

2.3 Microns/min

Avg. Decay Rate

0:33:44

Time to Ultimate P/D

0:00:26

Time in Decay

0:34:10

Total Elapsed Time

Customer

IMZ SDN BHD
 IOI BUSINESS PARK, 2F-15, GF12, LDP,
 BANDAR PUCHONG JAYA,
 PUCHONG, SELANGOR 47100

Equipment

Make: Mitsubishi Heavy Industry
Model: FDC335KXZXE1
Serial: A82700146KF

Other Stats

Ultimate Pull Down: 394.2 Microns
 Avg. Ambient Temp: 29.2°C
 Device Name: BluVac+ Pro
 Date: 19/03/2019
 Start Time: 18:54:36
 End Time: 19:28:47

Values

Notes

Evacuation is completed below 500 micron and decay test is passed for COMPRESSOR CIRCUIT (Indoor circuit is isolated).