



Attestation of Conformity

ISO/IEC, EN & TIA/EIA Unscreened Class E / Category 6 Four Connector Channel

DINTEK Electronic Ltd.
**No. 8, Lane 97, Wu -Kong Rd., Wu-Ku Industrial District,
Hsin Chuang, Taipei Hsien, Taiwan**

Attestation of Conformity No. 110701

type of Class E / Category 6 unscreened four connector channel has been tested by 3P Third Party Testing and complies with Class E channel requirements of 2nd Edition ISO/IEC 11801, amendment 1 to 2nd Edition ISO/IEC 11801, CENELEC EN 50173-1:2007 and amendment 1 to CENELEC EN 50173-1:2007 (Draft EN 50173-1 prAA June 2008), and Category 6 channel requirements of ANSI/TIA-568-C.2. The Attestation of Conformity is only valid for the actually tested channel samples in T568B configuration, and consisting of the following DINTEK Electronic components:

<i>Cables:</i>	<i>Horizontal Cable,</i>	<i>P/N 1101-0400X</i>
	<i>Flexible Cable,</i>	<i>From Patch Cords, P/N 1201-040XX</i>
	<i>Qualification Status:</i>	<i>Manufacturer verified</i>
<i>Conn. Hardware:</i>	<i>Keystone Jack,</i>	<i>P/N 1305-0401X</i>
		<i>having PCB marking LE000228 A9 E0246</i>
	<i>Patch Panel,</i>	<i>P/N 1402-0401X</i>
		<i>having PCB marking LE000422 A3-ROHS 8389</i>
	<i>Qualification Status:</i>	<i>Manufacturer Verified</i>
<i>Consolidation Cord:</i>	<i>2,0 m,</i>	<i>From Patch Cord, P/N 1201-0403X</i>
	<i>Qualification Status:</i>	<i>Manufacturer Verified</i>
<i>Equipment and Patch Cords:</i>	<i>3,0 m and 5,0 m</i>	<i>P/N 1201-040XX</i>
	<i>Qualification Status:</i>	<i>Manufacturer Verified</i>

Hoersholm, 27th April 2010

Ole Lambertsen

Ole Lambertsen
Test Responsible

Hoersholm, 27th April 2010

Paul Villien

Poul Villien
Coordinating Manager